

Laboratory Report

DATE REPORTED: 07/02/2025

CLIENT: South Georgia Fire District
PROJECT: WSID 5121 PBCU

WORK ORDER: 2506-20303
DATE RECEIVED: 06/27/2025

001 Site: 151 Ballard Rd. Kitchen Sink Date Sampled: 6/27/25 Time: 5:41

Facility ID: DS001 Smp Pt: LC001 Categ: PB Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	7/1/25 18:49	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	7/1/25 18:49	W RSB	A	

002 Site: 173 Cedarwood Terrace Kitchen Sink Date Sampled: 6/27/25 Time: 5:15

Facility ID: DS001 Smp Pt: LC001 Categ: PB Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	7/1/25 18:51	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	7/1/25 18:51	W RSB	A	

003 Site: 171 Meadow Ridge Lane Kitchen Sink Date Sampled: 6/27/25 Time: 6:25

Facility ID: DS001 Smp Pt: LC001 Categ: PB Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.073	mg/L	EPA 200.8	7/1/25 18:53	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	7/1/25 18:53	W RSB	A	

004 Site: 140 Musket Circle Kitchen Sink Date Sampled: 6/27/25 Time: 5:15

Facility ID: DS001 Smp Pt: LC001 Categ: PB Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	7/1/25 18:55	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	7/1/25 18:55	W RSB	A	

005 Site: 73 Sunset Circle Kitchen Sink Date Sampled: 6/27/25 Time: 8:41

Facility ID: DS001 Smp Pt: LC001 Categ: PB Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	7/1/25 18:57	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	7/1/25 18:57	W RSB	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.