

Laboratory Report

South Georgia Fire District 100509

73 Sunset Circle

Milton, VT 05468

Atten: Jeffrey Vance

PROJECT: WSID 5121 TC

WORK ORDER: 2501-00371

DATE RECEIVED: January 06, 2025

DATE REPORTED: January 07, 2025

SAMPLER: Jeffry Vance

VT0005121

001 Site: 53 Sunset Circle Kitchen Sink

Date Sampled: 1/6/25

Time: 15:45

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: RT Compl Ind: Y Repl Ind: N

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Total Coliform	ABSENT	/100mL	SM 9223B (-16)	1/6/25 16:50	W EPB	A	
E. coli	ABSENT	/100mL	SM 9223B (-16)	1/6/25 16:50	W EPB	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC 17025:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Harry B. Locker, Ph.D.
Laboratory Director

www.endynelabs.com

160 James Brown Dr., Williston, VT 05495
Ph 802-879-4333 Fax 802-879-7103

56 Etna Road, Lebanon, NH 03766
Ph 603-678-4891 Fax 603-678-4893