

Laboratory Report

DATE REPORTED: 01/28/2026

CLIENT: South Georgia Fire District

WORK ORDER: 2601-02306

PROJECT: WSD 5121 So Georgia FD VOC

DATE RECEIVED: 01/22/2026

001

Site: 292 Cedarwood

Date Sampled: 1/21/26 Time: 18:53

Facility ID:	TP001	Smp Pt:	EP001	Categ:	GE	Smp Type:	RT	Compl Ind:	Y	Repl Ind:	N						
Parameter																	
Result																	
Units																	
Method																	
Analysis Date/Time																	
Lab/Tech																	
NELAC																	
Qual.																	
VOC Potable Water																	
Dichlorodifluoromethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Chloromethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Vinyl chloride	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Bromomethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Chloroethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Trichlorofluoromethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,1-Dichloroethene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Methylene chloride	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Methyl-t-butyl ether (MTBE)	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
trans-1,2-Dichloroethene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,1-Dichloroethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
2,2-Dichloropropane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
cis-1,2-Dichloroethene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Bromochloromethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Chloroform	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,1,1-Trichloroethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Carbon tetrachloride	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,1-Dichloropropene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Benzene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,2-Dichloroethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Trichloroethene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,2-Dichloropropane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Dibromomethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Bromodichloromethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
cis-1,3-Dichloropropene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Toluene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
trans-1,3-Dichloropropene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,1,2-Trichloroethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Tetrachloroethene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,3-Dichloropropane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Dibromochloromethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Chlorobenzene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Ethylbenzene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,1,1,2-Tetrachloroethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Xylenes, Total	< 1.0						ug/L			EPA 524.2		1/27/26		W EEP		A	
Styrene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Bromoform	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Isopropylbenzene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,1,2,2-Tetrachloroethane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
Bromobenzene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
n-Propylbenzene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,2,3-Trichloropropane	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
2-Chlorotoluene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	
1,3,5-Trimethylbenzene	< 0.5						ug/L			EPA 524.2		1/27/26		W EEP		A	



ENDYNE Inc.

www.endynelabs.com

Laboratory Report

DATE REPORTED: 01/28/2026

CLIENT: South Georgia Fire District
 PROJECT: WSID 5121 So Georgia FD VOC

WORK ORDER: 2601-02306
 DATE RECEIVED: 01/22/2026

001 Site: 292 Cedarwood

Date Sampled: 1/21/26 Time: 18:53

Facility ID: TP001 Smp Pt: EP001 Categ: GE Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
4-Chlorotoluene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
t-Butylbenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
1,2,4-Trimethylbenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
s-Butylbenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
4-Isopropyltoluene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
1,3-Dichlorobenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
1,4-Dichlorobenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
1,2,3-Trimethylbenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	U	
n-Butylbenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
1,2-Dichlorobenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
1,2,4-Trichlorobenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
Hexachlorobutadiene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
Naphthalene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
1,2,3-Trichlorobenzene	< 0.5	ug/L	EPA 524.2	1/27/26	W EEP	A	
Surr. 1 (4-Bromofluorobenzene)	108	%	EPA 524.2	1/27/26	W EEP	A	
Surr. 2 (1,2-Dichlorobenzene d4)	113	%	EPA 524.2	1/27/26	W EEP	A	

002 Site: Trip Blank Not Needed

Date Sampled: 1/21/26 Time: 8:25

Facility ID: UNKNO Smp Pt: UNKNO Categ: UN Smp Type: UN Compl Ind: Y Repl Ind: U

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
No analysis							

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.