

Laboratory Report



South Georgia Fire District 100509
 73 Sunset Circle
 Milton, VT 05468
 Atten: Jeffrey Vance

PROJECT: WSID 5121 TC
 WORK ORDER: 2505-12781
 DATE RECEIVED: May 05, 2025
 DATE REPORTED: May 06, 2025
 SAMPLER: Jeffrey Vance

VT0005121

001 Site: Kitchen Sink 53 Sunset Circle Date Sampled: 5/5/25 Time: 11:05

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual
Total Coliform	ABSENT	/100mL	SM23 9223B (04)	5/5/25 13:28	W CM	A	
E. coli	ABSENT	/100mL	SM23 9223B (04)	5/5/25 13:28	W CM	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC 17025:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Harry B. Locker, Ph.D.
 Laboratory Director



160 James Brown Dr., Williston, VT 05495
 Ph 802-879-4333 Fax 802-879-7103

www.endynelabs.com

56 Etna Road, Lebanon, NH 03766
 Ph 603-678-4891 Fax 603-678-4893

